

DOUBLE WALL FACTORY BUILT DUCTWORK

- ALL DUCTWORK IS REQUIRED TO BE INSTALLED WITH THE MAXIMUM SUPPORT SPACING LISTED BELOW.
- FOR A COMPLETE LIST OF APPROVED SUPPORT METHODS, SEE THE ENTIRE INSTALLATION AND OPERATION MANUAL.
- DUCTWORK SHALL SLOPE NOT LESS THAN 1/16" PER LINEAR FOOT TOWARDS THE HOOD OR AN APPROVED GREASE COLLECTION RESERVOIR.
- WHERE HORIZONTAL DUCTS EXCEED 75 FEET IN LENGTH, THE SLOPE SHALL NOT BE LESS THAN 3/16" PER LINEAR FOOT.

VERTICAL			
TYPE	WALL SUPPORT (FT)	CURB SUPPORT (FT)	FLOOR SUPPORT (FT)
2R & 2R HT (5'-16')	20'	24'	24'
2R (18')	18'	24'	24'
3R & 3Z (5'-24')	10'	24'	24'
3Z (26'-36')	10'	20'	20'

REVISIONS	
DESCRIPTION	DATE
△	
△	
△	
△	
△	



Southern California Office

3002 Dow Ave., Suite 410, Tustin, CA 92780
 PHONE: (714) 957-1500 FAX: (919) 227-5975 EMAIL: reg86@capliveair.com



www.capliveair.com

www.caplive.com

caplive.com

ACTIVE

Southern California Office

3002 Dow Ave., Suite 410, Tustin, CA, 92780 PHONE: (714) 957-1500 FAX: (919) 227-5975 EMAIL: reg@active.com



TAFE
Southern California Office

Panda Express - Destin FL (D8086)
DESTIN, FL, 32540

DATE: 8/11/2021

DWG.#:
5033296

DRAWN BY: AH-86

SCALE:
3/4" = 1'-0"

MASTER DRAWING

SHEET NO.
12




All ideas, designs, arrangement and plans indicated or represented by this drawing are the property of Panda Express Inc. and were created for use on this specific project. None of these ideas, designs, arrangements or plans may be used by or disclosed to any person, firm, or corporation without the written permission of Panda Express Inc.

REVISIONS:

[illegible]

DRAWN BY:

PANDA PROJECT #: - S8-22-D8086
C&P PROJECT #: - 2200772



JOSE J. DIAZ-VELAZQUEZ

TRUE WARM AND WELCOME 2300
34898 EMERALD COAST PARKWAY
DESTIN, FL 32451

HOOD DETAIL PLAN

TRUE WARM & WELCOME 2300 R5